



**PERMIT SUBMITTAL CHECKLIST
NFPA 72 FIRE ALARM SYSTEMS**



CONTRACTOR INFORMATION:

- ✓ The designer and applicant contact information must be included in the submittal.
- ✓ The installer's means of qualification **MUST** be included.

CODE INFORMATION:

- ✓ The most current edition of NFPA 72 and NFPA 70 must be indicated.
- ✓ The installation type must be indicated: new installation or modification to an existing system.
- ✓ Information must be provided which indicates the scope of work proposed.
- ✓ A list of the proposed devices and/or appliances to be installed.
- ✓ It **MUST** be indicated if the system includes additional emergency communication systems, functions, and devices.

PLANS:

- ✓ Graphically indicates the location of all fire alarm system components and devices.
- ✓ Includes a graphic circuit diagram for all fire alarm system components.
- ✓ A device legend is provided.
- ✓ A sequence of operation matrix is provided.
- ✓ Battery and voltage drop calculations are provided.
- ✓ The plans are stamped by a NICET III- Fire Alarm Systems for Prescriptive Systems, or by a Professional Engineer (PE) registered in the State of Colorado for performance-based designs.

MATERIAL SUBMITTALS:

- ✓ Data sheets and manufacturer's information **MUST** be provided and clearly highlighted for all system components being used.

See NFPA 72, 7.2 Minimum Required Documentation for a comprehensive list of submittal requirements and the 2021 Edition of the International Fire Code